

Rainwater Tank Sample Results current to 7 June 2007

Metal	Nickel	Lead
Total Number of Samples	1539	1539
Average of Total Samples	0.022	0.009
Number exceeding guidelines*	369	285
- Average of exceeding samples	0.074	0.038
- Range of exceeding samples	(0.021-0.95)	(0.011-0.4)
- 90% of exceeding samples have values less than	0.14	0.09

* Australian Drinking Water Guideline value for Nickel is 0.02 mg/L

* Australian Drinking Water Guideline value for Lead is 0.01 mg/L

Please note this table will continually be updated